REVISIONS NOTES: UNLESS OTHERWISE SPECIFIED REV DESCRIPTION DATE APPROVED 1. DIMENSIONS MAY VARY - DO NOT USE FOR CONSTRUCTION 2. DIMENSIONS ARE IN INCHES DRAWING IS FOR CONCEPTUAL PURPOSES ONLY 4. ACTUAL COMPONENT SIZING MAY VARY BASED ON DESIGN CONDITIONS ALL CONNECTING PIPING MUST BE SUPPORTED CARBON STEEL INLET/OUTLET HEADERS 68.00 -_2" TANGENTIAL AIR SEPARATOR 61.00 2 GAL CHEMICAL FEEDER _8 GAL EXPANSION TANK 62.75 60.00 CARBON STEEL -"C" CHANNEL SKID W/ TOP PLATE ALLOW CLEARANCE FOR PANEL SERVICE _NEMA RATED CONTROL PANEL \emptyset 2.00" INLET 150# FLANGE TRIPLE DUTY VALVE ISOLATION (57.13) BRAIDED SST_ FLEX COUPLER END SUCTION -CLOSE COUPLED PUMP (1 RUN/2 STANDBY) SUCTION DIFFUSER-MOUNTING PLATE -LIFTING LUG PROPRIETARY AND CONFIDENTIAL TRIPLEX PUMP PACKAGE THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF PUROFLUX CORPORATION. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF PUROFLUX CORPORATION IS PROHIBITED. 2" PIPE HEADER REV RELEASE DATE 8-9-19 SCALE NONE WWW.PUROFLUX.COM SHEET 1 OF 1 S. REICHERT